



IMPORTANT: POWER TO THE FAN MUST BE PROVIDED BY THE EBC 24.  
DO NOT SHARE THE NEUTRAL WIRE FROM THE EBC 24 TO THE FAN.

Note:  
The wire sizes shown are typical and may not apply to all jobs. This system must be installed in compliance with the NFPA 70 National Electric Code and/or any local codes.

⊕ Not Connected      ⊕ Connected  
—— Factory Wired      --- Field Wired

PROPRIETARY AND CONFIDENTIAL

The information contained in this drawing is the sole property of ENERVEX, Inc. Any reproduction in part or as a whole without the express written consent of ENERVEX, Inc. is prohibited.

NOT TO SCALE

<b>ENERVEX</b> GREEN BEFORE GREEN WAS IN		1685 Bluegrass Lakes Pkwy Alpharetta, GA 30004 (770)587-3238 Fax (770)587-4731	
TITLE WIRING DIAGRAM		DATE 2/2/2024	
NAME EXHAUST ONLY - EBC 24 & GSV 009-016		JOB # GENERIC	
DWG BY AS	SHEET 2 OF 2	REV # 1	