



Fan		Motor	
Model	Voltage (V)	Input Voltage (V)	Current (A)
GSV 200	1x120	Max. 1x120V	1.4
GSV 250	1x120	Max. 1x120V	2.9
GSV 315	1x120	Max. 1x120V	5.8

Note:
The wire sizes shown are typical and may not apply to all jobs. This system must be installed in compliance with the NFPA 70 National Electric Code and/or any local codes.

PROPRIETARY AND CONFIDENTIAL
The information contained in this drawing is the sole property of ENERVEX, Inc. Any reproduction in part or as a whole without the express written consent of ENERVEX, Inc. is prohibited.

NOT TO SCALE

Line Voltage Low Voltage Signal

ENERVEX®
GREEN BEFORE GREEN WAS IN

1685 Bluegrass Lakes Pkwy
Alpharetta, GA 30004
(770)587-3238
Fax (770)587-4731

TITLE	CONNECTION DIAGRAM	DATE	2/2/2024
NAME	EXHAUST ONLY - EBC 24 & GSV 200-315	JOB #	Generic
DWG BY	AS	SHEET	1 OF 2
		REV	# 1